CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 7300-0410:160

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621-2268

Contact: Bob Misiuk (714) 670-3251 Fax (714) 690-7890

DESIGN: Models SBC-2, -2R, -4/12, -4/24 detector sounder base. The use of suffix "W" indicates

> the color white. Unit SBC-2R employs a relay. SBC-4 models employ extra output leads for connection to a control panel intitiating loop. Refer to listee's data sheet for additional

detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

Listed as detector base for use with separately listed functionally and electrically compatible APPROVAL:

> fire alarm control units. Designed specifically for use with listee's Models SIJ-24 (CSFM Listing No. 7271-0410:135) Ionization Smoke Detector or Models SLR-24V, SLR-835 (CSFM Listing No. 7272-0410:107) Photoelectric Smoke Detector. Refer to listee's Installation

Instruction Manual for details.

NOTE: These appliances can generate a distinctive three-pulse Temporal Pattern Fire Alarm

Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

10-27-03

OCTOBER 27, 2003 Date Issued: Listing Expires June 30, 2004

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager